

Certificate

No. **c8144a-23**

Customer:

ZVK GmbH
Technologiecampus 2
94244 Teisnach, Germany

Test sample(s):

data cable:

EasyLan® Data Cable Gold S/FTP AWG22/1 1500MHz Cat. 7A

Part no.: CESG1212K, CESG1212KD, CESG1213K, CESG1213KD, CESG1214K, CESG1214KD

connecting hardware:

EasyLan® Module fixLink® Cat. 6A RJ45

Part no.: CKFAK001, CKFAK001EP, CKWAK007, CKWAK007EP, CKFAK002, CKFAK002EP

Class Ea

Applied standard(s):

ISO/IEC 11801-1 Ed.1.0 (2017-11)

DIN EN 50173-1 (2018-10)

Result(s):

The sample meets the limits of the specified standards and regulations with respect to the parameters indicated above.

2 Connector Permanent Link, Copper, Class Ea

GHMT Type Approval

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report no. **R8144a-23** and shall only be applicable in conjunction with the test report. This certificate is valid 24 months after date of testing.

Bexbach, 11.08.2023



Dirk Wilhelm, engineer
(Chairman of the Managing Board)



Test laboratory accredited by DAKKS in accordance with DIN EN ISO/IEC 17025:2018.
The accreditation is valid for the test methods listed in certificate **D-PL-17559-01-00**.

GHMT AG

In der Kolling 320
66450 Bexbach / Germany

PO box 11 16
66442 Bexbach / Germany

T: +49 6826 92 28-0
F: +49 6826 92 28-290

info@ghmt.de
www.ghmt.de

**RELIABILITY IN TOTAL
REQUIRES ACCURACY IN DETAIL.**